

Certificate No: A3374_2

Project: Cable Ducts User Spec ENATS 12/24 Issue 2021

Client: Naylor Drainage Ltd.

Date: January 2026

This certificate is issued to NAYLOR INDUSTRIES PLC to certify that the undersigned testing facility did, at their request, complete the performance tests stipulated below on the following products:

1. Cable duct description:
Polyvinylchloride, nominal outside diameter 160mm, Class 1, rigid and non coilable
2. Standard Reference:
Technical Specification for plastic ducts for buried electric cables, Cable Duct User Spec ENATS 12/24 Issue 2021.
3. The following tests were completed:

Routine Test	Sample Test	Type Test
1. Construction	1. Dimensions	1. Marking and documentation
	1.1 - Inside diameter	2. Duct Assembly, by other means than threads
	1.2 - Ovality	3. Degree of protection
	1.3 - Length	4. Vicat softening test
	2. Compression test: Resistance to deformation at 23°C	5. Static friction coefficient test
	3. Impact test at -5°C	6. Resistance to deformation at 75°C (Class 1)
	4. Heat Reversion	

4. All results of tests stated in paragraph 3 are included in the client test schedule. The annexes mentioned in the test schedule are supporting documentation.
5. The results of the mentioned tests were found to be within the requirements of the Technical Specification for plastic ducts for buried electric cables, Cable Duct User Spec ENATS 12/24 Issue 2021.

Jeff Robertson
Operations Manager
EA Technology Ltd

Safer, Stronger, Smarter

Australia | China | UK | Singapore |

