



REPORT

# Certification of Polyvinylchloride Cable Ducts

Private and Confidential

Prepared for: Naylor

Report No: Cert

Document Version: Issue 1

Date: March 2026



Classification: Commercial In Confidence

## Version History

Date	Version	Author(s)	Notes
20/03/2026	Issue 1	Sara Griffiths	Certification of 1 duct size

CONFIDENTIAL - This document may not be disclosed to any person other than the addressee or any duly authorised person within the addressee's company or organisation and may only be disclosed so far as is strictly necessary for the proper purposes of the addressee which may be limited by contract. Any person to whom the document or any part of it is disclosed must comply with this notice. A failure to comply with it may result in loss or damage to EA Technology Ltd or to others with whom it may have contracted and the addressee will be held fully liable therefor.

Care has been taken in the preparation of this Report, but all advice, analysis, calculations, information, forecasts and recommendations are supplied for the assistance of the relevant client and are not to be relied on as authoritative or as in substitution for the exercise of judgement by that client or any other reader. EA Technology Ltd. nor any of its personnel engaged in the preparation of this Report shall have any liability whatsoever for any direct or consequential loss arising from use of this Report or its contents and give no warranty or representation (express or implied) as to the quality or fitness for the purpose of any process, material, product or system referred to in the report.

All rights reserved. No part of this publication may be reproduced or transmitted in any form or by any means electronic, mechanical, photocopied, recorded or otherwise, or stored in any retrieval system of any nature without the written permission of the copyright holder.

© EA Technology Ltd March 2026

EA Technology Limited, Capenhurst Technology Park, Capenhurst, Chester, CH1 6ES;

Tel: 0151 339 4181 Fax: 0151 347 2404

<http://www.eatechnology.com>

Registered in England number 2566313

**Classification: Commercial In Confidence**

**Certificate No: A3402\_3**

**Project: Cable Ducts User Spec ENATS 12/24 Issue 2021**

**Client: Naylor Drainage Ltd.**

**Date: March 2026**

This certificate is issued to NAYLOR DRAINAGE LTD to certify that the undersigned testing facility did, at their request, complete the performance tests stipulated below on the following products:

1. Cable duct description:

Polyvinylchloride, nominal outside diameter 160mm, Class 2, rigid and non coilable

2. Standard Reference:

Technical Specification for plastic ducts for buried electric cables, Cable Duct User Spec ENATS 12/24 Issue 2021.

3. The following tests were completed:

Routine Test	Sample Test	Type Test
1. Construction	1. Dimensions	1. Marking and documentation
	1.1 - Inside diameter	2. Duct Assembly, by other means than threads
	1.2 - Ovality	3. Degree of protection
	1.3 - Length	4. Vicat softening test
	2. Compression test: Resistance to deformation at 23°C	5. Static friction coefficient test
	3. Impact test at -5°C	6. Resistance to deformation at 50°C (Class 2)
	4. Heat Reversion	

4. All results of tests stated in paragraph 3 are included in the client test schedule. The annexes mentioned in the test schedule are supporting documentation.

5. The results of the mentioned tests were found to be within the requirements of the Technical Specification for plastic ducts for buried electric cables, Cable Duct User Spec ENATS 12/24 Issue 2021.

Sara Griffiths  
Materials Lab Technician  
EA Technology Ltd

Safer, Stronger, Smarter

Australia | China | UK | Singapore |





Safer, Stronger, Smarter Networks

EA Technology Limited  
Capenhurst Technology Park  
Capenhurst, Chester CH1 6ES

t +44 (0) 151 339 4181  
e [sales@eatechnology.com](mailto:sales@eatechnology.com)  
[www.eatechnology.com](http://www.eatechnology.com)